

Ren 2022 223 Appendix B - Summary Report - St. Thomas Aquinas

| Facility Name | Amenity | Description | On-site Observation | Requirement | Compliance |
|--------------------|--------------------------|--|---------------------|-------------|---------------|
| St. Thomas Aquinas | Parking Lot | Total Parking Stalls | 70 | N/A | |
| St. Thomas Aquinas | Parking Lot | Van Accessible Parking Space (Type A) | 1 | 2 | Non-compliant |
| St. Thomas Aquinas | Parking Lot | Limited Accessible Parking Space (Type B) | 0 | 2 | Non-compliant |
| St. Thomas Aquinas | Parking Lot | Compliant access aisles provided for Type A Spaces | No | Yes | Non-compliant |
| St. Thomas Aquinas | Exterior Walks | Quantity of exterior paths of travel to the facility from the municipal sidewalk or parking lot | 1 | N/A | |
| St. Thomas Aquinas | Exterior Walkways | Quantity of exterior path of travel with compliant width ($\geq 1100\text{mm}$) | 1 | All | Compliant |
| St. Thomas Aquinas | Exterior Walkways | Surface of the exterior path of travel is stable, slip-resistant | Yes | Yes | Compliant |
| St. Thomas Aquinas | Exterior Ramps | Number of non-compliant ramps (slope, width, surface, and/or landings) | 0 | None | Compliant |
| St. Thomas Aquinas | Building Entrances | Total Public Entrances | 1 | N/A | |
| St. Thomas Aquinas | Building Entrances | Total Designated Accessible Entrances (Entrances with automatic door openers) | 0 | 1 | Non-compliant |
| St. Thomas Aquinas | Building Entrances | Entrances with compliant clear width of open door ($\geq 860\text{mm}$) | 2 | 1 | Compliant |
| St. Thomas Aquinas | Building Entrances | Entrances with non-compliant clear width of open door ($< 860\text{mm}$) | 0 | None | Compliant |
| St. Thomas Aquinas | Building Entrances | Entrance vestibules with inner and outer doors with compliant clear width of open door ($\geq 860\text{mm}$) | 0 | All | Compliant |
| St. Thomas Aquinas | Building Entrances | Entrance vestibules with inner and/or outer doors with non-compliant clear width of open door ($< 860\text{mm}$) | 0 | None | Compliant |
| St. Thomas Aquinas | Building Entrances | Entrance vestibules without sufficient distance between doors ($< 1500\text{mm}$) | 0 | None | Compliant |
| St. Thomas Aquinas | Building Entrances | Step at entrance or elevated entrance without a ramp access | 2 | None | Non-compliant |
| St. Thomas Aquinas | Interior Entrances | Entrances with compliant clear width of open door ($\geq 860\text{mm}$) | 15 | All | Compliant |
| St. Thomas Aquinas | Interior Entrances | Entrances with non-compliant clear width of open door ($< 860\text{mm}$) | 42 | None | Non-compliant |
| St. Thomas Aquinas | Interior Entrances | Entrance vestibules with inner and outer doors with compliant clear width of open door ($\geq 860\text{mm}$) | 0 | All | Compliant |
| St. Thomas Aquinas | Interior Entrances | Entrance vestibules with inner and/or outer doors with non-compliant clear width of open door ($< 860\text{mm}$) | 0 | None | Compliant |
| St. Thomas Aquinas | Interior Entrances | Entrance vestibules without sufficient distance between doors ($< 1500\text{mm}$) | 0 | None | Compliant |
| St. Thomas Aquinas | Interior Paths of Travel | Number of Floors | 3 | N/A | |
| St. Thomas Aquinas | Interior Paths of Travel | Elevators/Lifts Available | No | Yes | Non-compliant |
| St. Thomas Aquinas | Interior Paths of Travel | Quantity of Compliant Elevators/Lifts Available | 0 | 1 | Non-compliant |
| St. Thomas Aquinas | Interior Paths of Travel | Quantity of non-compliant elevators without compliant dimensions and/or door open width | 0 | N/A | |

| | | | | | |
|--------------------|--------------------------|---|---------------|------------------|---------------|
| St. Thomas Aquinas | Interior Paths of Travel | Quantity of non-compliant elevators with compliant dimensions, but without compliant accessories/systems | 0 | N/A | |
| St. Thomas Aquinas | Interior Ramps | Number of non-compliant ramps (slope, width, surface, and/or landings) | 0 | None | Compliant |
| St. Thomas Aquinas | Service Counters | Quantity of locations with service counters | 1 | N/A | |
| St. Thomas Aquinas | Service Counters | Quantity of accessible service counters | 0 | At all locations | |
| St. Thomas Aquinas | Service Counters | Quantity of non-accessible service counters | 1 | N/A | Non-compliant |
| St. Thomas Aquinas | Fire Alarm System | Audible and visual signals available in the corridors | In some areas | Yes | Compliant |
| St. Thomas Aquinas | Fire Alarm System | Audible and visual signals available in the washrooms | No | Yes | Non-compliant |
| St. Thomas Aquinas | Universal Washroom | Quantity of designated universal washrooms | 4 | 1 | Compliant |
| St. Thomas Aquinas | Universal Washroom | Quantity of compliant universal washrooms | 0 | 1 | Non-compliant |
| St. Thomas Aquinas | Universal Washroom | Individual washrooms non-compliant dimensions and/or turning space diameter | 4 | N/A | |
| St. Thomas Aquinas | Universal Washroom | Individual washrooms with compliant dimensions, but without critical equipment (emergency call system, adult change table or provision of change table, etc.) | 0 | N/A | |
| St. Thomas Aquinas | Universal Washroom | Individual washrooms with compliant dimensions and critical equipment (emergency call system, adult change table, etc.), however, no compliant washroom accessories (soap dispensers, grab bar, etc.) | 0 | N/A | |
| St. Thomas Aquinas | Communal Washrooms | Quantity in Facility | 6 | N/A | |
| St. Thomas Aquinas | Communal Washrooms | Quantity within 45m of a universal washroom and has less than 4 water closets (These washrooms do not need to be compliant) | 0 | N/A | |
| St. Thomas Aquinas | Communal Washrooms | Quantity of non-compliant water closets | 4 | N/A | |
| St. Thomas Aquinas | Communal Washrooms | Quantity of non-compliant urinals | 2 | N/A | |
| St. Thomas Aquinas | Communal Washrooms | Quantity of non-compliant lavatories | 4 | N/A | |
| St. Thomas Aquinas | Communal Washrooms | Quantity of washroom entrances with automatic door opener | 0 | N/A | |
| St. Thomas Aquinas | Communal Washrooms | Quantity of washroom entrances without automatic door opener | 4 | N/A | |