

## Ren 2022 223 Appendix D - Summary Report - St. Joseph's Morrow Park

Facility Name	Amenity	Description	On-site Observation	Requirement	Compliance
St. Joseph's Morrow Park	Parking Lot	Total Parking Stalls	108	N/A	
St. Joseph's Morrow Park	Parking Lot	Van Accessible Parking Space (Type A)	5	3	Compliant
St. Joseph's Morrow Park	Parking Lot	Limited Accessible Parking Space (Type B)	0	3	Non-compliant
St. Joseph's Morrow Park	Parking Lot	Compliant access aisles provided for Type A Spaces	Yes	Yes	Compliant
St. Joseph's Morrow Park	Exterior Walks	Quantity of exterior paths of travel to the facility from the municipal sidewalk or parking lot	2	N/A	
St. Joseph's Morrow Park	Exterior Walkways	Quantity of exterior path of travel with compliant width ( $\geq 1100\text{mm}$ )	2	All	Compliant
St. Joseph's Morrow Park	Exterior Walkways	Surface of the exterior path of travel is stable, slip-resistant	Yes	Yes	Compliant
St. Joseph's Morrow Park	Exterior Ramps	Number of non-compliant ramps (slope, width, surface, and/or landings)	0	None	Compliant
St. Joseph's Morrow Park	Building Entrances	Total Public Entrances	4	N/A	
St. Joseph's Morrow Park	Building Entrances	Total Designated Accessible Entrances (Entrances with automatic door openers)	3	2	Compliant
St. Joseph's Morrow Park	Building Entrances	Entrances with compliant clear width of open door ( $\geq 860\text{mm}$ )	3	2	Compliant
St. Joseph's Morrow Park	Building Entrances	Entrances with non-compliant clear width of open door ( $< 860\text{mm}$ )	0	None	Compliant
St. Joseph's Morrow Park	Building Entrances	Entrance vestibules with inner and outer doors with compliant clear width of open door ( $\geq 860\text{mm}$ )	2	2	Compliant
St. Joseph's Morrow Park	Building Entrances	Entrance vestibules with inner and/or outer doors with non-compliant clear width of open door ( $< 860\text{mm}$ )	0	None	Compliant
St. Joseph's Morrow Park	Building Entrances	Entrance vestibules without sufficient distance between doors ( $< 1500\text{mm}$ )	0	None	Compliant
St. Joseph's Morrow Park	Building Entrances	Step at entrance or elevated entrance without a ramp access	0	None	Compliant
St. Joseph's Morrow Park	Interior Entrances	Entrances with compliant clear width of open door ( $\geq 860\text{mm}$ )	48	All	Compliant
St. Joseph's Morrow Park	Interior Entrances	Entrances with non-compliant clear width of open door ( $< 860\text{mm}$ )	0	None	Compliant
St. Joseph's Morrow Park	Interior Entrances	Entrance vestibules with inner and outer doors with compliant clear width of open door ( $\geq 860\text{mm}$ )	0	All	Compliant
St. Joseph's Morrow Park	Interior Entrances	Entrance vestibules with inner and/or outer doors with non-compliant clear width of open door ( $< 860\text{mm}$ )	0	None	Compliant
St. Joseph's Morrow Park	Interior Entrances	Entrance vestibules without sufficient distance between doors ( $< 1500\text{mm}$ )	0	None	Compliant
St. Joseph's Morrow Park	Interior Paths of Travel	Number of Floors	2	N/A	
St. Joseph's Morrow Park	Interior Paths of Travel	Elevators/Lifts Available	Yes	Yes	Compliant
St. Joseph's Morrow Park	Interior Paths of Travel	Quantity of Compliant Elevators/Lifts Available	0	1	Non-compliant
St. Joseph's Morrow Park	Interior Paths of Travel	Quantity of non-compliant elevators without compliant dimensions and/or door open width	1	N/A	

St. Joseph's Morrow Park	Interior Paths of Travel	Quantity of non-compliant elevators with compliant dimensions, but without compliant accessories/systems	0	N/A	
St. Joseph's Morrow Park	Interior Ramps	Number of non-compliant ramps (slope, width, surface, and/or landings)	0	None	Compliant
St. Joseph's Morrow Park	Service Counters	Quantity of locations with service counters	2	N/A	
St. Joseph's Morrow Park	Service Counters	Quantity of accessible service counters	1	At all locations	Compliant
St. Joseph's Morrow Park	Service Counters	Quantity of non-accessible service counters	1	0	Non-compliant
St. Joseph's Morrow Park	Fire Alarm System	Audible and visual signals available in the corridors	Yes	Yes	Compliant
St. Joseph's Morrow Park	Fire Alarm System	Audible and visual signals available in the washrooms	In some washrooms	Yes	Compliant
St. Joseph's Morrow Park	Universal Washroom	Quantity of designated universal washrooms	4	1	Compliant
St. Joseph's Morrow Park	Universal Washroom	Quantity of compliant universal washrooms	1	1	Compliant
St. Joseph's Morrow Park	Universal Washroom	Individual washrooms non-compliant dimensions and/or turning space diameter	1	N/A	
St. Joseph's Morrow Park	Universal Washroom	Individual washrooms with compliant dimensions, but without critical equipment (emergency call system, adult change table or provision of change table, etc.)	1	N/A	
St. Joseph's Morrow Park	Universal Washroom	Individual washrooms with compliant dimensions and critical equipment (emergency call system, adult change table, etc.), however, no compliant washroom accessories (soap dispensers, grab bar, etc.)	2	N/A	
St. Joseph's Morrow Park	Communal Washrooms	Quantity in Facility	3	N/A	
St. Joseph's Morrow Park	Communal Washrooms	Quantity within 45m of a universal washroom and has less than 4 water closets  (These washrooms do not need to be compliant)	0	N/A	
St. Joseph's Morrow Park	Communal Washrooms	Quantity of non-compliant water closets	6	N/A	
St. Joseph's Morrow Park	Communal Washrooms	Quantity of non-compliant urinals	0	N/A	
St. Joseph's Morrow Park	Communal Washrooms	Quantity of non-compliant lavatories	7	N/A	
St. Joseph's Morrow Park	Communal Washrooms	Quantity of washroom entrances with automatic door opener	2	N/A	
St. Joseph's Morrow Park	Communal Washrooms	Quantity of washroom entrances without automatic door opener	2	N/A	